



# RESIDENTIAL

## PLUMBING DIVISION INSPECTION REPORT

DATE: \_\_\_\_\_ SECTOR \_\_\_\_\_

INSPECTOR: \_\_\_\_\_

PHONE: 313 -224-3202

SUPERVISOR: \_\_\_\_\_

Rough  Final

# SAMPLE

<b>Job Location:</b>		<b>Permit No.</b>
<b>Owner:</b>	<b>Address:</b>	
<b>Contractor:</b>	<b>Address:</b>	

( X ) THE FOLLOWING ORDERS ARE ISSUED AND CORRECTIONS MADE ON OR BEFORE \_\_\_\_\_

### ROUGH INSPECTIONS

RR10	1. <input type="checkbox"/> Provide license plumber on jobsite to stand rough plumbing inspection., <input type="checkbox"/> Post building permit on jobsite, <input type="checkbox"/> Provide approved plans on jobsite. Sec. 602.3, Sec. 110.6, Sec. 605 Ord. 256-H as mended.
RR12	2. Test rough plumbing: <input type="checkbox"/> Underground, <input type="checkbox"/> Aboveground, <input type="checkbox"/> Finish plumbing, <input type="checkbox"/> Water distribution. P2503, MRC 2006.
RR14	3. <input type="checkbox"/> Uncover plumbing installed without inspection. P2503.2, MRC 2006.
RR58	4. <input type="checkbox"/> Properly vent: P3101.2.1 MRC 2006.

### FINAL INSPECTIONS

RR34	5. <u>Water Heater install the following:</u> <input type="checkbox"/> Relief valve, <input type="checkbox"/> Proper size, length, material for relief valve discharge pipe, <input type="checkbox"/> Code approved gas valve, <input type="checkbox"/> Full- open flow valve, <input type="checkbox"/> Properly secure diverter and fume pipe, <input type="checkbox"/> Eliminate back drafting at water heater, <input type="checkbox"/> Vacuum relief valve, <input type="checkbox"/> Code approved drain pan, <input type="checkbox"/> Properly seal fume pipe at chimney, <input type="checkbox"/> Provide drain valve. P2801.2 MRC 2006.
RR28	6. <input type="checkbox"/> Install an approved shower control valve. P2708.3 MRC 2006.
RR36	7. <input type="checkbox"/> Install brass converter fitting or dielectric fitting between the copper and galvanized steel piping. P2904.17.1 MRC 2006.
RR46	8. Properly install: <input type="checkbox"/> Water closet, <input type="checkbox"/> Lavatory, <input type="checkbox"/> Bathtub, <input type="checkbox"/> Other _____ P2705 MRC.2006
RR24	9. <input type="checkbox"/> Immediately remove obstruction from: _____ Sec. 105.2, 105.3 Ord. 256 -H as amended.
RR26	10. <input type="checkbox"/> Provide access to slip connection: <input type="checkbox"/> Bathtub, <input type="checkbox"/> Other: 2704.1 MRC 2006.
RR42	11. <input type="checkbox"/> Install backwater valve for: P3008 MRC 2006.
RR50	12. <input type="checkbox"/> Install water hammer arrester(s) for: P2903.5 MRC 2006.
RR52	13. <input type="checkbox"/> Install water control valve(s) at: <input type="checkbox"/> Service to dwelling <input type="checkbox"/> Water heater <input type="checkbox"/> Riser <input type="checkbox"/> Branches <input type="checkbox"/> Hose connection, <input type="checkbox"/> Fixture: <input type="checkbox"/> Appliance: P2903.10, P2903.9 MRC 2006.
RR56	14. <input type="checkbox"/> Provide gas and water tight joints for: P2904.8 MRC 2006.

(OVER)

